

Register of Completed Embedded Generation Projects

Document number:	SOP 33-05B		
Issue number:	6		
Status:	Approved		
Approver:	Suresh Damani		
Date of approval:	27/06/2022		

This register includes the details, as specified under clause 5.4.5 of the National Electricity Rules, for all completed embedded generation projects that have connected to AusNet Services distribution network since 1 October 2009. Permission has been sought from the respective Embedded Generators to publish this information. Any confidential information has been omitted from this register. AusNet Services will update this register by the DAPR date each year.

Register of Completed Embedded Generation Projects

Name	Location	Technology of generating unit including make and model	Maximum power generation capacity of all embedded generating units comprised in the relevant generating system	Contribution to fault levels	Size and rating of the relevant transformer	A single line diagram of the connection arrangement	Protection systems and Communications Systems	Voltage control and reactive power capability
Project #1	Hampton Park, Victoria	Synchronous (bioenergy) Make: Caterpillar Model: 3516LE	8.9MW	1.45 kA (3ph, @ 22kV sub- transient)	8x 1.25 MVA	Refer to the connection diagram within this document	Remote Trip and SCADA	Voltage control: Yes (22kV Voltage Set Point) Rreactive power capability per engine: 1.1 MVAr absolute maximum export capability. However, the connection agreement regulates power factor to range: 0.95 lag (supplying 0.37MVAr) to 0.95 lead (absorbing 0.37MVAr).
Project #2	Wollert, Victoria	Synchronous (bioenergy) Make: Caterpillar Model: 3516LE	8.9MW	1.14 kA (3ph, @ 22kV sub- transient)	7x 1.25MVA + 1x 2.50MVA	Refer to the connection diagram within this document	Remote Trip and SCADA	Voltage control: Yes (22.66kV Voltage Set Point) Reactive power capability per engine: 1.1 MVAr absolute maximum export capability. However, the connection agreement regulates power factor to range: 0.95 lag (supplying 0.37MVAr) to 0.95 lead (absorbing 0.37MVAr).
Project #3	Traralgon, Victoria	Synchronous (gas engine) Make: Caterpillar	10MW	1.37(3ph-g) kA	12.5MVA	Refer to the connection diagram within this document	Remote controlled switch - TN198 & SCADA to incomer CB	Voltage control: No Reactive power capability: 0 MVAr
Project #4	Seymour, Victoria	Asynchronouse Make: Vestas Model: V136-3.6MW	55MW	Three phase fault current, approx. 0.55 kA	70MVA	Refer to the connection diagram within this document	Remote Trip and SCADA	Voltage control: 5% voltage droop with a 1.02pu control target Reactive power capability: AAS
Project #5	Benalla, Victoria	Asynchronous Generator Make: Huawei Model: SUN2000-90KTL	85MW	Three phase fault current. 1.5kA; Single phase to ground fault current, 1.5kA; Phase to phase to ground fault current, 1.5kA	100MVA (33/66)		Remote Trip and SCADA	Voltage control: Voltage droop control (4%), target voltage of 1.03 pu @ GNTS Reactive power capability: 33.6MVAr (Q injection and absorption) at 40°C. 30.26 MVAr (Q injection and absorption) at 50°C. Q injection: when the connection point voltage is in the range of 83.97%-88.99% of nominal voltage. Q absorption: when the connection point voltage is in the range of 114%-117% of nominal voltage.
Project #6	South Gippsland, Victoria	Asynchronous Generator Make: Senvion SE Model: Senvion SE MM92		At 66kV Connection Point LSSS1: 3 phase = 1.32 kA, 1 phase = 0.32kA 4t 66kV Connection Point LSSS2: 3 phase = 1.43 kA, 1 phase = 0.29kA	Dyn 11 ONAF	Refer to the connection diagram within this document	Protection: Current differential protection with Distance backup (line), CB Fail, Auto reclose (at LGA and WGI only, no reclose at wind farm), Anti-Islanding Scheme, Runback Scheme Communication Systems: Current differential protection, Remote Trip, SCADA, Anti-Islanding Scheme, Runback Scheme	Voltage control: 0.99 lagging Power Factor (absorbing reactive power). Seek to maintain voltage between 0.95 and 1.05p.u at
Project #7	Glenrowan West, North Victoria	Asynchronous Generator Make: SMA Sunny Central Model: SC 2750EV	110MW	Three phase fault current, 2.0kA; Single phase to ground fault current, 2.0 kA; Phase to phase to ground fault current, 2.0 kA	142MVA, (33/66)	Refer to the connection diagram within this document	Remote Trip and SCADA	Voltage control: Voltage droop control (4%), target voltage of 1.03 pu @ CNTS Reactive power capability: 43.45MVAr (Q injection and absorption) at 35°C. 39.5 MVAr (Q injection and absorption) at 50°C.













